



Certificate of Compliance

Certificate: 1111695 (LR 116214)

Master Contract: 200116

Project: 1889423

Date Issued: 2007/03/21

Issued to: International Hydraulics, Inc.

7638 St Clair Ave
Mentor, OH 44060
USA

Attention: Charles Ridley

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Nick Sajatovich

Authorized by: Nick Alfano, Operations Manager

PRODUCTS

CLASS 6223 82 - WIRE CONNECTING DEVICES - Wire Connectors - Certified to US Standards

CLASS 6223 02 - WIRE CONNECTING DEVICES - Wire Connectors

Wire connectors, Cat. No. B2 and B2C, for use with wire sizes 2-8 AWG aluminum and 2-14 AWG copper conductors; Cat. No. B6B, for use with wire sizes 6-8 AWG aluminum and 6-14 AWG copper conductors;

Cat. No. B1/0, for use with wire sizes 8-1/0 AWG copper and aluminum conductors; Cat. No. B4B, for use with 4-14 AWG copper conductors only.

Wire connector, Cat. No. B1/0, for use with wire sizes 8-1/0 AWG copper and aluminum conductors; Cat. No.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1111695 (LR 116214)

Master Contract: 200116

Project: 1889423

Date Issued: 2007/03/21

B4B, for use with 4-14 AWG copper conductors only.

APPLICABLE REQUIREMENTS

CSA Standard C22. 2 No. 65-03 - Wire Connectors

UL Standard 486A (1st Edition) - Wire Connectors and Soldering Lugs for Use with Copper Conductors.

UL Standard 486B (1st Edition) - Wire Connectors for Use with Aluminum Conductors.