



**International Hydraulics Inc.**

**ihconnectors.com™**

<b>Wire Size</b>	<b>Rated Torque</b>
------------------	---------------------

10-14 AWG	35 IN. LBS.
-----------	-------------

8 AWG	40 IN. LBS.
-------	-------------

4-6 AWG	45 IN. LBS.
---------	-------------

2-3 AWG	50 IN. LBS.
---------	-------------

**2-14 CU7**

**2-8 AL7**



200116



ZM VV2

To be used with

“Conditions of Acceptability”

**File E129884**

**Pressure Terminal  
Connectors**

NRTL Cat. No.

**B2**

Installation Instructions



[ihconnectors.com/b2.htm](http://ihconnectors.com/b2.htm)

# Conditions of Acceptability COA

Cat No. B2 and B2C

File E129884

Vol. 1      Sec. 16  
and Report

Page 1

Issued: 2000-10-16  
Revised: 2004-02-13

## Conditions of Acceptability -

1. Copper bus cross section and temperature rating.

<u>Cat. No.</u>	<u>Minimum Cross Section</u>	<u>Temperature Rating, °C</u>
4513-3, B2, B2C	0.240 by 0.040 in.	75

2. The connectors shall be prevented from turning by close fitting walls or the equivalent.

3. Cat. No. 4513, or B2, or B2C may be mounted to a copper bus 1/4 by 1/32 in. cross section but is then limited for use in equipment with a maximum rating of 50 A.

4. Cat. Nos. 4513-3, B2, or B2C have the capability of using either a slotted or recessed hex head screw. The tightening torque marking on the end product shall correspond to that required for the type of screw design being used.