



1. WIRE RANGE 2/0-14CU , 2/0-12AL
2. CONNECTOR TO BE UL LISTED OR RECOGNIZED FO TERMINATING COPPER AND ALUMINUM CONDUCTORS.
3. WIRE CLAMPING SCREW : ALUMINUM ALLOY, 7/16-20X5/8 RECESSED HEX DRIVE, 3/16 ACROSS FLATS, DOME SHAPPED BOTTOM.
4. TIGHTENING TORQUE : WITH WIRE INSTALLED, TORQUE IN ISE IS 120 IN-LBS FOR ALL WIRE SIZES
5. MARKING SHALL INCLUDE THE FOLLOWING:
  - MANUFACTURER'S NAME/LOGO ( IHI )
  - PART NUMBER ( 4444 )
  - WIRE RANGE ( 2/0-14 )
  - ( AL7CU )
  - UL RECOGNITION MARK ( UR )

NOT FOR USE WHERE FAILURE CREATES A HAZARD TO HUMAN HEALTH OR SAFETY. ALL PRODUCTS ARE SUBJECT TO THIS FULL DISCLAIMER:  
<http://www.ihiconnectors.com/disclaimer.html>

FOR FURTHER INFORMATION ON THE PROPER USE OF THIS PRODUCT IN SPECIFIC APPLICATIONS SEE  
<http://www.ihiconnectors.com/Technical-Data-Installation.htm>

REVISION HISTORY				
REV	DESCRIPTION	DATE	APPROVED	
1	REDRAWN IN SOLIDS	12/2/2008	Tim Smith	
<small>THIS DRAWING AND DESIGN ARE THE PROPERTY OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO, AND MAY NOT BE DUPLICATED, USED FOR THE BASIS OF DESIGN OR MANUFACTURE WITHOUT THE WRITTEN PERMISSION OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO.</small>		<b>INTERNATIONAL HYDRAULICS, INC.</b>		
GENERAL TOLERANCES ±.015 (±0.038)		<b>TITLE:</b> <b>4444</b> <b>CONNECTOR</b>		
<b>MATERIAL:</b> <b>6061-T6</b> <b>(11931)</b>	<b>SIZE:</b> <b>TDS</b>	<b>DRAWN BY:</b> <b>TDS</b>	<b>DWG NO.:</b> <b>4444-(SALES)</b>	<b>REV:</b> <b>1</b>
<b>FINISH:</b> <b>TIN PLATE</b> <b>EMS</b>	<b>DATE:</b> <b>12/02/08</b>	<b>THIS IS A CAD DRAWING, DO NOT MANUALLY REVISE</b>		