


MARK #14969rev.1

NOTES;
 1) PARTS MARKED:
 350 KCMIL - 6 UL LOGO
 CU9AL CSA LOGO
 2S350 IHI LOGO



DOUBLE MARK PERMITTED

Cat. No. 2S350 Style No. ALL
 ■ Drill, Enlarge, or Modify Mounting Holes
 1) Increase hole(s) dia. to 5/8 bolt (.641 drill dia.)
 2) Move location of mounting hole(s)
 3) If buying blank lug, put custom hole(s) in.

IHI UL/CSA Installation Guide to Drill or Enlarge Mounting Holes:
<https://lugsdirect.com/PDF%20Documents/IHI-MTG-HOLE-FIELD-MODS-UL&CSA-CERTIFICATIONS.pdf>

1. USE 2 x 1/2" (12mm) BOLTS AT 1-3/4" OR 2.0" SPACING
2. ZMVV CATEGORY RATED FOR GROUNDING, POWER DISTRIBUTION, POWER COLLECTION OR PARELLING IN PAIRS OF WIRES (1 PAIR or 2 PAIRS)
3. UL & CSA CATALOG NO: "2S350"

NOT FOR USE WHERE FAILURE CREATES A HAZARD TO HUMAN HEALTH OR SAFETY. ALL PRODUCTS ARE SUBJECT TO THIS FULL DISCLAIMER: <http://www.ihconnectors.com/disclaimer.html>

FOR FURTHER INFORMATION ON THE PROPER USE OF THIS PRODUCT IN SPECIFIC APPLICATIONS SEE <http://www.ihconnectors.com/GuideToFlexFlexibleFineStrandedWireCableMechanicalLugsFAQ.html>

<http://www.ihconnectors.com/Technical-Data-Installation.htm>

THIS DRAWING AND DESIGN ARE THE PROPERTY OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO, AND MAY NOT BE DUPLICATED, USED FOR THE BASIS OF DESIGN OR MANUFACTURE WITHOUT THE WRITTEN PERMISSION OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO.				
UNLESS OTHERWISE SPECIFIED: 1. DIMENSIONS ARE IN INCHES 2. REMOVE ALL BURRS AND SHARP EDGES 3. TOLERANCE ON DIMENSIONS: +/- .015				
INTERNATIONAL HYDRAULICS, INC.				
TITLE: 4S350-56-88 -SALES 4 HOLE, 6AWG-350KCMIL				
MATERIAL: AL. EXTRUSION - X1020	SIZE: A	DRAWN BY: DJH	DWG NO.: 4S350-56-88	REV: 1
FINISH: TIN ON AL.; EMS	DATE: 6/12/2015	THIS IS A CAD DRAWING, DO NOT MANUALLY REVISE		