



IHI UL/CSA Installation Guide to Drill or Enlarge Mounting Holes:
<https://lugsdirect.com/PDF%20Documents/IHI-MTG-HOLE-FIELD-MODS-UL&CSA-CERTIFICATIONS.pdf>

1. USE 2 x 1/2" (12mm) BOLTS AT 1-3/4" OR 2.0" SPACING
2. ZMVV CATEGORY RATED FOR GROUNDING, POWER DISTRIBUTION, POWER COLLECTION OR PARELLING IN PAIRS OF WIRES (1 PAIR or 2 PAIRS)
3. UL & CSA CATALOG NO: "2S350"

NOT FOR USE WHERE FAILURE CREATES A HAZARD TO HUMAN HEALTH OR SAFETY. ALL PRODUCTS ARE SUBJECT TO THIS FULL DISCLAIMER: <http://www.ihiconnectors.com/disclaimer.html>

FOR FURTHER INFORMATION ON THE PROPER USE OF THIS PRODUCT IN SPECIFIC APPLICATIONS SEE <http://www.ihiconnectors.com/GuideToFlexFlexibleFineStrandedWireCableMechanicalLugsFAQ.html>

<http://www.ihiconnectors.com/Technical-Data-Installation.htm>

<small>THIS DRAWING AND DESIGN ARE THE PROPERTY OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO, AND MAY NOT BE DUPLICATED, USED FOR THE BASIS OF DESIGN OR MANUFACTURE WITHOUT THE WRITTEN PERMISSION OF INTERNATIONAL HYDRAULICS, INC., CLEVELAND, OHIO.</small>					INTERNATIONAL HYDRAULICS, INC.				
<small>UNLESS OTHERWISE SPECIFIED: 1. DIMENSIONS ARE IN INCHES 2. REMOVE ALL BURRS AND SHARP EDGES 3. TOLERANCE ON DIMENSIONS: +/- .015</small>					TITLE: 4S350-56-88 -SALES 4 HOLE, 6AWG-350KCMIL				
MATERIAL: AL. EXTRUSION - X1020		SIZE: A	DRAWN BY: DJH	DWG NO.: 4S350-56-88	REV: 1				
FINISH: TIN ON AL.; EMS		DATE: 6/12/2015		THIS IS A CAD DRAWING, DO NOT MANUALLY REVISE					