



IHI UL/CSA Installation Guide to Drill or Enlarge Mounting Holes: https://lugsdirect.com/PDF%20Documents/IHI-MTG-HOLE-FIELD-MODS-UL&CSA-CERTIFICATIONS.pdf









MARKING S350 350 KCMIL-6 CU9AL IHI CSA LOGO UL LOGO

## Cat No. S350 Style No. 1

- Drill, Enlarge, or Modify Mounting Holes
- 1) Increase hole(s) dia. to 9/16 bolt
- 2) Move location of mounting hole(s)
- 3) If buying blank lug, put custom hole(s) in.

NOT FOR USE WHERE FAILURE CREATES A HAZARD TO HUMAN HEALTH OR SAFETY. ALL PRODUCTS ARE SUBJECT TO THIS FULL DISCLAIMER: http://www.ihiconnectors.com/disclaimer.html

FOR FURTHER INFORMATION ON THE PROPER USE OF THIS PRODUCT IN SPECIFIC APPLICATIONS SEE http://www.ihiconnectors.com/GuideToFlexFlexibleFineStrandedWireCableMechanicalLugsFAQ.html http://www.ihiconnectors.com/Technical-Data-Installation.htm

## FLEX WIRE 262 KCMIL - 4 AWG

THIS DRAWING AND DESIGN ARE THE PROPERTY OF INTERNATIONAL HYDRAULICS, INC., QLEVELAND, CHIO, AND MAY NOT BE DUPLICATED,	INTERNATIONAL HYDRAULICS, INC.			
USED FOR THE BASIS OF DESIGN OR MANUFACTURE WITHOUT THE WRITTEN PERMISSION OF INTERNATIONAL HYDRALLICS, INC., CLEVELAND, OHI C.	TITLE: \$350			
GENERAL TOLERANCES ±.015 (±0,038)	CONNECTOR			
MATERIAL: 6061-T6 (X0010)	SIZE:	DRAWN BY: TDS	S350-(SALES)	REV:
FINISH:TIN PLATE EMS	DATE: 12/10/08		THIS IS A CAD DRAWING, DO NOT MANUALLY REVISE	